| | | | |
|---|---|---|---|
| Pure Water Labs - Lodi | Project: 2026 Drinking Water Testing | | |
| 924 Development Dr Unit C | Project Number: 2026 Drinking Water Testing | **Reported:** | **Work Order:** |
| Lodi, WI 53555 | Project Manager: Jamie Stietz | 3/17/26 14:08 | CE02094 |

**Sample: ThermaStor Filter**

**CE02094-03 (DW) Sampled: 03/02/26 14:00**

| Analyte | Result | Qualifier | LOD | LOQ | MCL | Units | Date Prepared | Date Analyzed | Analyst | Method | Laboratory FID |
|---|---|---|---|---|---|---|---|---|---|---|---|
| **Metals** Analytes: 32 | | | | | | | | | | | |
| Turbidity, screening - SDWA (200.8) | ND | | 0.50 | 0.50 | 1 | NTU | 3/5/26 8:25 | 3/5/26 12:45 | SBB | EPA 180.1, Rev 2 | 2 |
| Aluminum, Total | ND | | 0.013 | 0.043 | 0.2 | mg/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Antimony, Total | ND | | 0.15 | 0.50 | 6 | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Arsenic, Total | ND | | 1.1 | 3.7 | 10 | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Barium, Total | 53 | | 0.20 | 0.67 | 2000 | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Beryllium, Total | ND | | 0.060 | 0.20 | 4 | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Boron, Total | 23 | | 4.6 | 15 | | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Cadmium, Total | ND | | 0.12 | 0.40 | 5 | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Calcium, Total | 9.0 | | 0.35 | 1.2 | | mg/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Chromium, Total | ND | | 1.2 | 4.0 | 100 | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Cobalt, Total | ND | | 0.045 | 0.15 | 40 | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Copper, Total | ND | | 0.69 | 2.3 | 1300 | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Iron, Total | ND | | 0.12 | 0.40 | | mg/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Lead, Total | ND | | 0.36 | 1.2 | 15 | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Magnesium, Total | 5.5 | | 0.024 | 0.080 | | mg/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Manganese, Total | 1.3 | J | 0.50 | 1.7 | 50 | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Mercury, Total | ND | | 0.021 | 0.070 | 2 | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Molybdenum, Total | ND | | 0.57 | 1.9 | | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Nickel, Total | ND | | 1.2 | 4.0 | 100 | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Potassium, Total | 1.6 | | 0.060 | 0.20 | | mg/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Selenium, Total | ND | | 1.0 | 3.3 | 50 | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Silicon, Total | 83 | | 20 | 67 | | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Silver, Total | ND | | 0.43 | 1.4 | 100 | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Sodium, Total | 0.35 | J | 0.14 | 0.47 | | mg/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Strontium, Total | 7.5 | | 0.31 | 1.0 | | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Thallium, Total | ND | | 1.2 | 4.0 | 2 | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Tin, Total | ND | | 1.5 | 5.0 | | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Titanium, Total | 1.2 | J | 0.45 | 1.5 | | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Uranium, Total | ND | | 0.049 | 0.16 | 30 | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Vanadium, Total | ND | | 1.1 | 3.7 | | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Zinc, Total | 4.1 | J | 3.8 | 13 | 5000 | ug/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | EPA 200.8, Rev 5.4 | 2 |
| Hardness unfiltered by ICPMS | 45 | | | | | mg/L | 3/9/26 9:30 | 3/9/26 15:20 | RAB | CALC | |

*The contents of this report apply to the sample(s) analyzed in accordance with the chain of custody document.*
*No duplication of this report is allowed, except in its entirety.*

| | | | |
|---|---|---|---|
| Pure Water Labs - Lodi | Project: 2026 Drinking Water Testing | | |
| 924 Development Dr Unit C | Project Number: 2026 Drinking Water Testing | **Reported:** | **Work Order:** |
| Lodi, WI 53555 | Project Manager: Jamie Stietz | 3/17/26 14:08 | CE02094 |

**Sample: ThermaStor Filter (Continued)**

**CE02094-03 (DW) Sampled: 03/02/26 14:00**

| Analyte | Result | Qualifier | LOD | LOQ | MCL | Units | Date Prepared | Date Analyzed | Analyst | Method | Laboratory FID |
|---|---|---|---|---|---|---|---|---|---|---|---|
| **Volatiles** Analytes: 60 | | | | | | | | | | | |
| Benzene | ND | | 0.17 | 0.57 | 5 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Bromobenzene | ND | | 0.19 | 0.63 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Bromodichloromethane | ND | | 0.23 | 0.77 | 80 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Bromoform | ND | | 0.24 | 0.80 | 80 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Bromomethane | ND | | 0.30 | 1.0 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Carbon Tetrachloride | ND | | 0.30 | 1.0 | 5 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Chloroethane | ND | | 0.25 | 0.83 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Chloroform | ND | | 0.24 | 0.80 | 80 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Chloromethane | ND | | 0.27 | 0.90 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 2-Chlorotoluene | ND | | 0.21 | 0.70 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 4-Chlorotoluene | ND | | 0.19 | 0.63 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Dibromochloromethane | ND | | 0.24 | 0.80 | 80 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Dibromomethane | ND | | 0.22 | 0.73 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,3-Dichlorobenzene | ND | | 0.28 | 0.93 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,2-Dichlorobenzene | ND | | 0.32 | 1.1 | 600 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,4-Dichlorobenzene | ND | | 0.29 | 0.97 | 75 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Dichlorodifluoromethane | ND | | 0.22 | 0.73 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,1-Dichloroethane | ND | | 0.21 | 0.70 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,2-Dichloroethane | ND | | 0.22 | 0.73 | 5 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,1-Dichloroethene | ND | | 0.31 | 1.0 | 7 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| cis-1,2-Dichloroethene | ND | | 0.23 | 0.77 | 70 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| trans-1,2-Dichloroethene | ND | | 0.20 | 0.67 | 100 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Dichloromethane | ND | | 0.18 | 0.60 | 5 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,2-Dichloropropane | ND | | 0.16 | 0.53 | 5 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,3-Dichloropropane | ND | | 0.24 | 0.80 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 2,2-Dichloropropane | ND | | 0.24 | 0.80 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,1-Dichloropropene | ND | | 0.25 | 0.83 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,3-Dichloropropene (Total cis+trans) | ND | | 0.51 | 1.7 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Ethyl Benzene | ND | | 0.21 | 0.70 | 700 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Hexachlorobutadiene | ND | | 0.36 | 1.2 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Isopropylbenzene | ND | | 0.21 | 0.70 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| p-Isopropyltoluene | ND | | 0.30 | 1.0 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |

*The contents of this report apply to the sample(s) analyzed in accordance with the chain of custody document.*
*No duplication of this report is allowed, except in its entirety.*

| | | | |
|---|---|---|---|
| Pure Water Labs - Lodi | Project: 2026 Drinking Water Testing | | |
| 924 Development Dr Unit C | Project Number: 2026 Drinking Water Testing | **Reported:** | **Work Order:** |
| Lodi, WI 53555 | Project Manager: Jamie Stietz | 3/17/26 14:08 | CE02094 |

**Sample: ThermaStor Filter (Continued)**

**CE02094-03 (DW) Sampled: 03/02/26 14:00**

| Analyte | Result | Qualifier | LOD | LOQ | MCL | Units | Date Prepared | Date Analyzed | Analyst | Method | Laboratory FID |
|---|---|---|---|---|---|---|---|---|---|---|---|
| **Volatiles (Continued)** Analytes: 60 | | | | | | | | | | | |
| MTBE | ND | | 0.24 | 0.80 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Chlorobenzene | ND | | 0.20 | 0.67 | 100 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Naphthalene | ND | | 0.19 | 0.63 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Styrene | ND | | 0.19 | 0.63 | 100 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,1,1,2-Tetrachloroethane | ND | | 0.31 | 1.0 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,1,2,2-Tetrachloroethane | ND | | 0.28 | 0.93 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Tetrachloroethene | ND | | 0.25 | 0.83 | 5 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Toluene | ND | | 0.20 | 0.67 | 1000 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,2,4-Trichlorobenzene | ND | | 0.28 | 0.93 | 70 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,1,1-Trichloroethane | ND | | 0.23 | 0.77 | 200 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,1,2-Trichloroethane | ND | | 0.21 | 0.70 | 5 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Trichloroethene | ND | | 0.22 | 0.73 | 5 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Trichlorofluoromethane | ND | | 0.33 | 1.1 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,2,3-Trichloropropane | ND | | 0.20 | 0.67 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,2,4-Trimethylbenzene | ND | | 0.26 | 0.87 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,3,5-Trimethylbenzene | ND | | 0.23 | 0.77 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Vinyl Chloride | ND | | 0.18 | 0.60 | 0.2 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Xylene (Total) | ND | | 0.24 | 0.80 | 10000 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,2,3-Trichlorobenzene | ND | | 0.31 | 1.0 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,2-Dibromo-3-Chloropropane (DBCP) | ND | | 0.39 | 1.3 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,2-Dibromoethane (EDB) | ND | | 0.21 | 0.70 | 0.05 | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Bromochloromethane | ND | | 0.21 | 0.70 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| n-Butylbenzene | ND | | 0.36 | 1.2 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| n-Propylbenzene | ND | | 0.23 | 0.77 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| sec-Butylbenzene | ND | | 0.28 | 0.93 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| tert-Butylbenzene | ND | | 0.31 | 1.0 | | ug/L | 3/11/26 14:00 | 3/11/26 20:55 | JLG | EPA 524.2, Rev 4.1 | 2 |
| *Surrogate: (SURR) 4-Bromofluorobenzene* | *77%* | | *Limits: 36-122%* | | | | *3/11/26 14:00* | *3/11/26 20:55* | *JLG* | *EPA 524.2, Rev 4.1* | |
| *Surrogate: (SURR) 1,2-Dichlorobenzene-d4* | *76%* | | *Limits: 42-127%* | | | | *3/11/26 14:00* | *3/11/26 20:55* | *JLG* | *EPA 524.2, Rev 4.1* | |

*The contents of this report apply to the sample(s) analyzed in accordance with the chain of custody document.*
*No duplication of this report is allowed, except in its entirety.*

| | | | |
|---|---|---|---|
| Pure Water Labs - Lodi | Project: 2026 Drinking Water Testing | | |
| 924 Development Dr Unit C | Project Number: 2026 Drinking Water Testing | **Reported:** | **Work Order:** |
| Lodi, WI 53555 | Project Manager: Jamie Stietz | 3/17/26 14:08 | CE02094 |

**Sample: Trip Blank**

**CE02094-04 (DW) Sampled: 03/02/26 00:00**

| Analyte | Result | Qualifier | LOD | LOQ | MCL | Units | Date Prepared | Date Analyzed | Analyst | Method | Laboratory FID |
|---|---|---|---|---|---|---|---|---|---|---|---|
| **Volatiles** Analytes: 60 | | | | | | | | | | | |
| Benzene | ND | | 0.17 | 0.57 | 5 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Bromobenzene | ND | | 0.19 | 0.63 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Bromodichloromethane | ND | | 0.23 | 0.77 | 80 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Bromoform | ND | | 0.24 | 0.80 | 80 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Bromomethane | ND | | 0.30 | 1.0 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Carbon Tetrachloride | ND | | 0.30 | 1.0 | 5 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Chloroethane | ND | | 0.25 | 0.83 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Chloroform | ND | | 0.24 | 0.80 | 80 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Chloromethane | ND | | 0.27 | 0.90 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 2-Chlorotoluene | ND | | 0.21 | 0.70 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 4-Chlorotoluene | ND | | 0.19 | 0.63 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Dibromochloromethane | ND | | 0.24 | 0.80 | 80 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Dibromomethane | ND | | 0.22 | 0.73 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,3-Dichlorobenzene | ND | | 0.28 | 0.93 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,2-Dichlorobenzene | ND | | 0.32 | 1.1 | 600 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,4-Dichlorobenzene | ND | | 0.29 | 0.97 | 75 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Dichlorodifluoromethane | ND | | 0.22 | 0.73 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,1-Dichloroethane | ND | | 0.21 | 0.70 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,2-Dichloroethane | ND | | 0.22 | 0.73 | 5 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,1-Dichloroethene | ND | | 0.31 | 1.0 | 7 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| cis-1,2-Dichloroethene | ND | | 0.23 | 0.77 | 70 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| trans-1,2-Dichloroethene | ND | | 0.20 | 0.67 | 100 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Dichloromethane | ND | | 0.18 | 0.60 | 5 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,2-Dichloropropane | ND | | 0.16 | 0.53 | 5 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,3-Dichloropropane | ND | | 0.24 | 0.80 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 2,2-Dichloropropane | ND | | 0.24 | 0.80 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,1-Dichloropropene | ND | | 0.25 | 0.83 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,3-Dichloropropene (Total cis+trans) | ND | | 0.51 | 1.7 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Ethyl Benzene | ND | | 0.21 | 0.70 | 700 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Hexachlorobutadiene | ND | | 0.36 | 1.2 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Isopropylbenzene | ND | | 0.21 | 0.70 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| p-Isopropyltoluene | ND | | 0.30 | 1.0 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |

*The contents of this report apply to the sample(s) analyzed in accordance with the chain of custody document.*
*No duplication of this report is allowed, except in its entirety.*

| | | | |
|---|---|---|---|
| Pure Water Labs - Lodi | Project: 2026 Drinking Water Testing | | |
| 924 Development Dr Unit C | Project Number: 2026 Drinking Water Testing | **Reported:** | **Work Order:** |
| Lodi, WI 53555 | Project Manager: Jamie Stietz | 3/17/26 14:08 | CE02094 |

**Sample: Trip Blank (Continued)**

**CE02094-04 (DW) Sampled: 03/02/26 00:00**

| Analyte | Result | Qualifier | LOD | LOQ | MCL | Units | Date Prepared | Date Analyzed | Analyst | Method | Laboratory FID |
|---|---|---|---|---|---|---|---|---|---|---|---|
| **Volatiles (Continued)** Analytes: 60 | | | | | | | | | | | |
| MTBE | ND | | 0.24 | 0.80 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Chlorobenzene | ND | | 0.20 | 0.67 | 100 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Naphthalene | ND | | 0.19 | 0.63 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Styrene | ND | | 0.19 | 0.63 | 100 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,1,1,2-Tetrachloroethane | ND | | 0.31 | 1.0 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,1,2,2-Tetrachloroethane | ND | | 0.28 | 0.93 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Tetrachloroethene | ND | | 0.25 | 0.83 | 5 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Toluene | ND | | 0.20 | 0.67 | 1000 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,2,4-Trichlorobenzene | ND | | 0.28 | 0.93 | 70 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,1,1-Trichloroethane | ND | | 0.23 | 0.77 | 200 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,1,2-Trichloroethane | ND | | 0.21 | 0.70 | 5 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Trichloroethene | ND | | 0.22 | 0.73 | 5 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Trichlorofluoromethane | ND | | 0.33 | 1.1 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,2,3-Trichloropropane | ND | | 0.20 | 0.67 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,2,4-Trimethylbenzene | ND | | 0.26 | 0.87 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,3,5-Trimethylbenzene | ND | | 0.23 | 0.77 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Vinyl Chloride | ND | | 0.18 | 0.60 | 0.2 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Xylene (Total) | ND | | 0.24 | 0.80 | 10000 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,2,3-Trichlorobenzene | ND | | 0.31 | 1.0 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,2-Dibromo-3-Chloropropane (DBCP) | ND | | 0.39 | 1.3 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| 1,2-Dibromoethane (EDB) | ND | | 0.21 | 0.70 | 0.05 | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| Bromochloromethane | ND | | 0.21 | 0.70 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| n-Butylbenzene | ND | | 0.36 | 1.2 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| n-Propylbenzene | ND | | 0.23 | 0.77 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| sec-Butylbenzene | ND | | 0.28 | 0.93 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| tert-Butylbenzene | ND | | 0.31 | 1.0 | | ug/L | 3/13/26 13:54 | 3/13/26 21:23 | JLG | EPA 524.2, Rev 4.1 | 2 |
| *Surrogate: (SURR) 4-Bromofluorobenzene* | *96%* | | *Limits: 36-122%* | | | | *3/13/26 13:54* | *3/13/26 21:23* | *JLG* | *EPA 524.2, Rev 4.1* | |
| *Surrogate: (SURR) 1,2-Dichlorobenzene-d4* | *95%* | | *Limits: 42-127%* | | | | *3/13/26 13:54* | *3/13/26 21:23* | *JLG* | *EPA 524.2, Rev 4.1* | |

*The contents of this report apply to the sample(s) analyzed in accordance with the chain of custody document.*
*No duplication of this report is allowed, except in its entirety.*

| | | | |
|---|---|---|---|
| Pure Water Labs - Lodi | Project: 2026 Drinking Water Testing | | |
| 924 Development Dr Unit C | Project Number: 2026 Drinking Water Testing | **Reported:** | **Work Order:** |
| Lodi, WI 53555 | Project Manager: Jamie Stietz | 3/17/26 14:08 | CE02094 |

## Laboratory Facility Identifications

| Code | Description | Number | Expires |
|---|---|---|---|
| 2 | NLS (Crandon) WDNR Laboratory ID No. | 721026460 | 8/31/26 |

*The contents of this report apply to the sample(s) analyzed in accordance with the chain of custody document.*
*No duplication of this report is allowed, except in its entirety.*

| | | | |
|---|---|---|---|
| Pure Water Labs - Lodi | Project: 2026 Drinking Water Testing | | |
| 924 Development Dr Unit C | Project Number: 2026 Drinking Water Testing | **Reported:** | **Work Order:** |
| Lodi, WI 53555 | Project Manager: Jamie Stietz | 3/17/26 14:08 | CE02094 |

## Qualifiers and Definitions

| Item | Definition |
|---|---|
| Rec-SCANq | The metals results are provided as a semi-quantitative scan and should not be used for compliance reporting. |
| J | Result is between LOD and LOQ and considered to be within a region of less-certain quantitation. |
| ND | Analyte NOT DETECTED at or above the LOD or MRL. |
| LOD | Limit of Detection. |
| LOQ | Limit of Quantitation. |
| NA | Not Applicable. |
| Dry | Dry Weight Basis. |
| Wet | Wet Weight Basis. |
| % Dry | Equal to: (mg/kg dry) / 10000. |
| 1000 ug/L | Equal to: 1 mg/L. |
| MCL | Maximum Contaminant Levels for Drinking Water Samples. Shaded results indicate >MCL. |
| RPD | Relative Percent Difference. |
| %REC | Percent Recovery. |
| Source | Sample that was matrix spiked or duplicated. |

All LOD/LOQs adjusted to reflect preparation volumes, dilutions, and/or solids content.

*The contents of this report apply to the sample(s) analyzed in accordance with the chain of custody document.*
*No duplication of this report is allowed, except in its entirety.*